



**NOTES:**

1. MAXIMUM WIDTH OF TRENCH AT TOP OF PIPE IS 30" FOR PIPE UP TO AND INCLUDING 12" NOMINAL DIAMETER. FOR PIPE LARGER THAN 12" NOMINAL DIAMETER MAX. WIDTH SHALL BE PIPE O.D. PLUS 16".
2. EXCAVATE UNSTABLE MATERIAL DOWN TO FIRM SOIL AND REPLACE WITH FOUNDATION GRAVEL PER SECTION 9-03.9(3), "BALLAST", OF THE WSDOT STANDARD SPECIFICATIONS.
3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANCHORING PIPE TO PREVENT FLOTATION DURING CONCRETE PLACEMENT.
4. COMPACTED CRUSHED SURFACING PER SECTION 9-03.9(3), "CRUSHED SURFACING", OF THE WSDOT STANDARD SPECIFICATIONS CAN ALSO BE USED AS BEDDING GRAVEL.



**City of  
Bellevue**

**SEWER UTILITIES**

**TITLE**

**PIPE BEDDING**

**NO. S-15**